



Fire Inspection Letter CSFPD

Inspection Information

Inspector: Neil, Scot
Inspection Type: Re-Inspection
Date Completed: 09/06/2024
Occupancy ID: 2150100
Passed: Yes
Inspection Number: 202408083039

Occupancy Information

Name: Jigars Kitchen
Street Address: 281 Commonwealth Drive
City State Zip: Carol Stream, Illinois 60188
Phone: (630) 362-0685
Email: info@jigarskitchen.com

Primary Contact

Primary Contact Name: Jigar Parikh
Business Name: Jigar's Kitchen
Cell Phone: 630-362-0685
Work Phone:
Email: info@jigarskitchen.com

Violations

Violation Code	Description	Reinspection Date
904.12.5	Automatic fire-extinguishing systems protecting commercial cooking systems shall be maintained in accordance with Sections 904.12.5.1 through 904.12.5.3. Overdue for service	08/23/2024 Repaired: 09/06/2024 14:34:34
607.3.3	Hoods, grease-removal devices, fans, ducts and other appurtenances shall be cleaned at intervals as required by Sections 607.3.3.1 through 607.3.3.3. Appliances have been rearranged so that some do not have fire protection.	08/23/2024 Repaired: 09/06/2024 14:34:19

An inspection of your facility was conducted, if there are any violations listed above, please make corrections by re-inspection date.

ORDER TO COMPLY: Since these conditions are contrary to law, you must correct them upon receipt of this notice. An inspection to determine compliance with this Notice will be conducted on or about the posted re-inspection date.

If you fail to comply with this notice before the reinspection date listed, you may be liable for the penalties provided for by law for such violations.

A fee will be assessed when occupancies require more than a second re-inspection to verify that corrections have been made for deficiencies found during the initial inspection. The fee will be applied as follows:

\$50.00 - Third re-inspection

\$100.00 - Fourth and all additional re-inspections