

# KANKAKEE FIRE DEPARTMENT

## INSPECTION REPORT

LORI'S DINER, 362-64 E COURT ST, BLDG UNNAMED, KANKAKEE IL 60901

### DETAILS

Inspection Date: 07/17/2024 | Inspection Type: Inspection | Inspection Number: 57473-R3 | Shift: N/A | Station: Station 1 | Unit: N/A | Lead Inspector: DAVID MOY | Other Inspectors: N/A

### VIOLATIONS AND COMPLIANCES

No Violations or Compliances selected to show for this inspection. Please reach out to the lead inspector for more details.  
Resolved Violations: 2 | Passed Codes: 0 | Violations: 0 | N/A Codes: 0

### GENERAL NOTES

DAVID MOY - 06/17/2024 @ 15:06

Spoke with owner still waiting on contractor

DAVID MOY - 06/17/2024 @ 15:06

Periodic cooking in a gas stove in the basement. Suppression system was out of service. Suppression system need to be in service and inspected annually or cooking discontinued in basement as shown by stoves being disconnected from gas line.


### NEXT INSPECTION DATE

04/06/2025

### CONTACT SIGNATURE

Miguel Puebla

Signed on: 07/17/2024 @ 10:41



### INSPECTOR SIGNATURE

DAVID MOY

Signed on: 07/17/2024 @ 10:43



**QUESTIONS ABOUT YOUR INSPECTION?**

DAVID MOY  
damoy@citykankakee-il.gov  
8159330458